



Fuel Gas & Mechanical Inspection Information

This is only a general information list and is not intended to address all possible conditions. All inspections will fall under the 2012 International Residential Code and adopted ordinances.

General

- ✓ Job address is posted in a visible location. (R319- R105.7)
- ✓ Manufacturer's installation information is available if needed. (G2408.1)
- ✓ Main shutoff is accessible and located on the supply side of meter. (G2420.2)
- ✓ Testing is required only for new pipe added to an existing system.
- ✓ Air test should be applied to system with an unbroken and in working order gauge. Apply 10 psi test. Per Spring Hill
- ✓ Sleeved gas line that runs thru foundation block or other wall that could cause damage to line. (2415.9)
- ✓ Bollard or wheel stop required if subject to impact by automobile.(M1307.3.1)
- ✓ Ducts, boots and connectors used for heating or cooling insulated to R-8 in unconditioned spaces and to R- 6 in crawl space.(N1103.2.1)