

City of Spring Hill  
 199 Town Center Parkway  
 P.O. Box 789  
 Spring Hill, TN 37174  
 Phone: 931.486.2252 ext. 211  
 Fax: 931.486.3596



For additional information, send inquiries to:  
 Beau Herring (bherring@springhilltn.org)

**APPLICATION FOR BACKFLOW PERMIT**

=====

Name of Project: _____	
Address of Project: _____	
General Contractor: _____	Foreman: _____
Contractor Address: _____	
Phone: _____	Fax: _____
Plumber Utility Contractor: _____	License: _____
Phone: _____	Fax: _____
Plumber Address: _____	
How many backflow assemblies are planned? _____	

<b>Backflow Assembly Information:</b>
<input type="checkbox"/> Containment at Meter
<input type="checkbox"/> Isolation at Cross Connection
<input type="checkbox"/> Fire Service
<input type="checkbox"/> Irrigation Service

**BACKFLOW ASSEMBLY INSTALLATION GUIDE**

1. The backflow assembly should be as close to the water meter as possible. In all cases, it shall be before the first branch in the water service. Call the City for more information about isolation backflow assemblies.
2. Reduced pressure assemblies shall be installed at least 12 inches above the finish grade, flood level or floor.
3. The maximum installation height of a backflow assembly is sixty inches.
4. An enclosure shall be provided that protects the assembly from theft, vandalism, tampering, weather & frost. (For Commercial Use)
5. In the floor, underground and vault installations are prohibited. (For Irrigation Use)
6. There shall be 12 inches clearance on all sides of the assembly.
7. Electrical equipment, outlets and breaker boxes shall not be located beneath the assembly.
8. Only in-line testable assemblies approved by the TN Division of Water.
9. The type of assembly shall be appropriate for the hazard as identified by the Cross Connection Control Office.
10. Prior to installing assemblies, it is recommended that the Cross Connection Control Office be contacted to verify that the type of assembly being used is appropriate for the hazards.
11. Installation, relocation or replacement of backflow prevention assemblies requires a City of Spring Hill permit and inspection.
12. Backflow assemblies shall be tested by a certified tester within 30 days of the installation and annually thereafter.
13. Permit must be on job site.

I have read the backflow assembly installation requirements above and will abide by said requirements.

\_\_\_\_\_  
**Applicant Signature / Date**

\_\_\_\_\_  
**City Staff Signature / Date**

<input type="checkbox"/> Approved <input type="checkbox"/> Denied	Permit #: _____	Permit Fees: _____
---	-----------------	--------------------