

RESOLUTION No. 98-10

**A RESOLUTION TO AUTHORIZE THE WASTE WATER SUPERINTENDENT
TO PURCHASE SURFACE RADIAL AERATORS
TO REPLACE THE ASPIRATING AERATORS,
SUCH PURCHASE TO OCCUR
AS THE ASPIRATING AERATORS FAIL IN SERVICE**

Whereas, the existing Aero-2 aspirating (vertical) aerators now in use at the waste water plant have repeatedly failed and been repaired in a never ending cycle, and


Whereas, the aspirating aerators were never the most efficient at adding oxygen to the water and, in any event, should be replaced for functionality, and

Whereas, rather than repeated cost of failure repair until the new WWTP comes on line, the WW superintendent and the WW plant design consultant have mutually agreed that new radial (horizontal) aerators can later be used in the new plant and are much more efficient at oxygen enrichment of the effluent, and

Whereas, the policy has been proposed that a new radial aerator should be purchased for each of the existing aspirating aerators as such existing aerator shall fail

THEREFORE BE IT RESOLVED BY THE BOARD OF MAYOR AND ALDERMEN of the Town of Spring Hill, that the waste water superintendent is authorized, empowered and directed to advertise, bid and purchase as replacement units, the aspirating aerators with new radial aerators as the former become non-functional due to mechanical failure of the unit and that funds for such shall be drawn in amounts necessary for purchase from the waste water reserve funds


Passed and adopted by the Board of Mayor and Aldermen on the 16th day of March, 1998.


RON HANKINS, MAYOR

ATTEST:


JUNE QUIRK, RECORDER

LEGAL FORM APPROVED:


M. ANDREW HOOVER, ATTORNEY